

Water / Building & Grounds Report Feb 2018

Installed post and chain across front walk
Has annual fire alarm inspection office passed note Highway barn needs
replacing
Plowed
Picked up office supplies form county
Washed all trucks
Installed meter 2884 main
Serviced F350 truck found rust hole in tranny oil pan replaced
Replaced back flow unit on boilers
Marked dig requests
Took class in Hornell 3.5CEC
Painted inside Hornby rd meter house
Ran CM generator on load for 1 HR
Replaced lights in town hall that were out
Did 2 hr OSHA safety training
Cleaned chlorine units
Exercised main line valves from Goff rg up 352,Gorton and Main st
Helped highway with broken door
Spent 1 Hr in Caltin replacing o rings in a fire hyd