

Water / Building & Grounds Report March 2018

Storm took out power on Timberline Generator ran 64 hr
Salted lots and walks
Took excel class
Put up posted signs and trail cam at Gibson tank
Got new recorder for clerk
Had Hornby rd RPZ valve certified
Rebuilt chlorine pump in Gibson then switched CM and Gibson
Load ran EC generator for 1 hr
Talked with Jody Allen about Dutton rd she is going to do a quote
John received his D license from doh
Got heat gun and removed all decals from trucks for sale
Cleaned and set up shop for rabies clinic
Opened and locked shop for rabies clinic
Read meters and sent out bills
Timberline generator alarmed during weekly test talked with tech put it
under load and seemed fine
Has few reports for white stuff falling out of water after it was boiled it is
calcium and is normal this time of year talked with DOH
Took dig safe class

Things I need on agenda for April meeting
Discussion on equipment on auction
Will there be a pay raise for John now that he has a DOH license?
Discussion on Dutton rd form Jody Allen

