

Water / Building & Grounds Report

Nov 2018

Samples

Took Jeep to Chilson's for recall

Sent out Relevy letters

Did interment

Had roof put on CM PRV house

Had meeting with EJP on GIS

Installed new lights on tractor

Prepared for snow storm

Plowed and salted

Installed new light in CM and Hornby road pump houses

Leak on charts in pinewood 11/24/18

Looked for leak had City of Corning in with there leak finding equipment, Village of South Corning helped us look and listen, On wed the 28 NY leak detection cam in and narrowed down the area. It was located later that night on a line behind the CCC Library we shut off the Library that night and fixed first thing in morning. My phone fell into hole and was buried.